



**Partnership to Advance Clean Energy-Deployment (PACE-D)  
Technical Assistance Program**

**Energy Conservation Building Code – 2016  
National Expert Consultation Workshop**

**New Delhi**

May 27, 2016

## Presentation Overview

1. Session – 1 – ECBC Background and ECBC 2016 Development Process & Methodology
2. Session – 2 – Administration and Compliance
3. Session – 3 – Building Envelope
4. Session – 4 – Lighting and Controls
5. Session – 5 – Comfort Systems and Controls
6. Session – 6 – Electrical and Renewable
7. Session – 7 – Discussion and Way forward

Session - 1

# ECBC Background and ECBC 2016 development Process & Methodology

## Energy Conservation (EC) Act, 2001

1. Energy Conservation Act was enacted in 2001
2. Specifies powers of Central and State Government.
3. Bureau of Energy Efficiency was established under this Act
4. As per the Act
  - a. **energy conservation building codes** means the norms and standards of energy consumption expressed in terms of per m<sup>2</sup> of the area wherein energy is used and includes the location of the building
  - b. **“building”** means any structure or erection (or part), after the rules relating to ECBC have been notified, which is having a connected load of 100kW or contract demand of 120 kVA and above and is intended to be used for commercial purposes


## EC Act, 2001 – Powers to Central Government

1. Specify any user as a designated consumer (14 e)
2. Prescribe Energy Conservation Building Codes (14 p)
3. Amend the ECBC (14 q)
4. Direct buildings to comply with ECBC (14 r)
5. Create awareness and conduct training programs (14 t)

## EC Act, 2001 – Powers to State Government

1. Amend the ECBC (15 a)
2. Notify ECBC (15 a)
3. Direct buildings to comply with the ECBC (15 c)
4. Create awareness and conduct training programs (15 e)
5. Designate inspecting agency (17 – 1)

## Energy Conservation Building Code 2007



- Fulfills the requirement of EC Act 2001
- Launched by Ministry of Power in May 2007
- Purpose – Minimum requirement for the EE design and construction
- Applicable to commercial buildings with connected load greater than 100 kW or contract demand greater than 120 kVA (2009 amendment)

27 May 2016 - Delhi

ECBC Update 2016

7

## ECBC implementation status in India




- ECBC amendment (20):
  - Odisha, Punjab, Karnataka, Rajasthan, Andhra Pradesh, Telangana, Uttara khand, UT of Puducherry, Uttar Pradesh, Kerala, Gujarat, Tamil Nadu, Haryana, Chhattisgarh, Maharashtra, West Bengal, Himachal Pradesh, Bihar, Madhya Pradesh, Assam, Goa

27 May 2016 - Delhi

ECBC Update 2016

8

## ECBC implementation status in India




- States completed ECBC notification (10)
  - Odisha
  - Punjab
  - Karnataka
  - Rajasthan
  - Andhra Pradesh
  - Telangana
  - Uttara khand
  - UT of Puducherry
  - Haryana
  - West Bengal

27 May 2016 - Delhi


ECBC Update 2016

9

## Worldwide Status of Building Energy Codes – Non Residential



Sources: Janda, K.B. "Worldwide Status of Energy Standards for Buildings: A 2009 Update." 2009 ECEEE (European Council for an Energy Efficient Economy) Proceedings; Environmental Change Institute, Oxford University; Building Codes Assistance Project (BCAP).





27 May 2016 - Delhi

ECBC Update 2016

10

## Worldwide Status of Building Energy Codes – Residential



27 May 2016 - Delhi

ECBC Update 2016

11

## Vision for ECBC 2016

- In the 12<sup>th</sup> Plan, ECBC update is a priority
- nZEB target for India
- Mandatory implementation and enforcement of ECBC
- Response to the technological advancement
- Response energy scenario of India

27 May 2016 - Delhi

ECBC Update 2016

12

## Key objectives of ECBC 2016 development

1. Focus on passive strategies
2. Ease of compliance
3. Establish a baseline of energy performance
4. Address different building types in various climatic zones
5. Increase the purview of ECBC
6. Integrate other government policy standards into ECBC (S&L program, building Star rating etc)

27 May 2016 - Delhi

ECBC Update 2016

13

## ECBC update committee



27 May 2016 - Delhi

ECBC Update 2016

14

## ECBC update committee structure

### ECBC Steering Committee

Chair: Director General (DG), BEE,  
 Convener: Energy Economist (EE), BEE  
 Members: USAID, UNDP, MNRE, MoUD, SDAs, BIS, IGBC, GRIHA

1:  
 Administration  
 and  
 Compliance  
 working group

2:  
 Building  
 Envelope  
 working group

3:  
 Comfort  
 systems and  
 controls  
 working group

4:  
 Lighting &  
 Controls  
 working group

5:  
 Electrical &  
 Renewable  
 working group

### ECBC Technical Committee

Chair: Energy Economist (EE), BEE  
 Convener: Asst. Energy Economist (AEE), BEE  
 Members: Chair of the individual technical Working Groups  
 Building sector Stakeholders: BIS, CPWD, Indian Railways, MES, SDAs, CREDAI,  
 Builder community, Bilateral and NGO Organization

27 May 2016 - Delhi

ECBC Update 2016

15

## Steering Committee

Chair - Director General, Bureau of Energy Efficiency

Other members - MNRE, MoUD, BIS, CPWD, SDA, USAID, UNDP,  
 IGBC, USGBC, GRIHA

Planned meetings –

1. Proposed in June 2016
2. These meetings to continue till the code is ready for notification

27 May 2016 - Delhi

ECBC Update 2016

16



## Administration and Compliance

1. **Chair - Mr. Sanjay Seth, Bureau of Energy Efficiency**
2. **Convener - Mr. Girja Shankar, Bureau of Energy Efficiency**

### Members

1. Mr. Srinivas Chary, Administrative Staff College of India
2. Mr. K. K. Joadder, Town & Country Planning Organization
3. Mr. C. K. Verma, Central Public Works Department
4. Mr. Sumit Sengar, Bureau of Indian Standards
5. Mr. Sunit Mathur, State Designated Agency- Rajasthan
6. Mr. C. S. Prasad, Indian Building Congress
7. Mr. C. Shekhar Reddy, CREDAI
8. Chair of all other Working Groups

27 May 2016 - Delhi

ECBC Update 2016

17

## Building Envelope

1. **Chair - Dr. N. K. Bansal, Ex Prof – IIT Delhi**
2. **Convener - Mr. Girja Shankar, Bureau of Energy Efficiency**

### Members

1. Ar. Sanjay Prakash, SHiFt: Studio for Habitat Futures
2. Ar. Ashok B. Lall, Ashok B Lall Architects
3. Ar. Vinod Gupta, Space Design Consultants
4. Mr. Prabhakar Singh, Central Public Works Department
5. Ar. Anurag Bajpai, Green Tree
6. Dr. Rajan Rawal, Center for Environmental Planning & Technology
7. Ms. Mili Majumdar, TERI

27 May 2016 - Delhi

ECBC Update 2016

18

## Lighting and Controls

1. **Chair** - Late Mr. H. S. Mamak.

**Mr. Gulshan Aghi, Ex- President of ISLE**

1. **Convener** - Mr. Girja Shankar, Bureau of Energy Efficiency

### Members

1. Mr. Shyam Sujan, ELCOMA
2. Mr. Prabhakar Singh, Central Public Works Department
3. Mr. Rajeev Sharma, CPWD
4. Dr. S. K. Bhattacharyya, Central Building Research Institute Roorkee
5. Dr. H C Kandpal, Independent Consultant
6. Mr. Deepak Gupta, Halonix
7. Mr. H. R. Vaish, ISLE
8. Mr. P. K. Sood, ISLE

27 May 2016 - Delhi

ECBC Update 2016

19

## Comfort Systems and Controls

1. **Chair** - Dr. R. S. Agarwal, Ex Professor Indian Institute of Technology Delhi

2. **Convener** - Mr. Girja Shankar, Bureau of Energy Efficiency

### Members

1. Dr. Milind V Rane, Indian Institute of Technology Mumbai
2. Mr. G C Modgil, Sterling India
3. Mr. Ashwini Mehra, ISHRAE
4. Mr. Ashish Rakheja, AEON
5. Mr. R. K. Mehta, Mr. Seemant Sharma, and Mr. Rahul Garg, RAMA
6. Dr. Rajan Rawal, CEPT
7. Dr. Jyotirmay Mathur, Malaviya National Institute of Technology, Jaipur
8. Ms. Archana Walia, CLASP

27 May 2016 - Delhi

ECBC Update 2016

20

## Electrical and Renewable

1. **Chair - Dr. Bhim Singh, Professor and Dept Head, IIT Delhi**
2. **Convener - Mr. Girja Shankar, Bureau of Energy Efficiency**

### Members

1. Mr. Vivek Arora, Indian Electrical and Electronics Manufacturers Association
2. Mr. Arun K Tripathi, Ministry of New and Renewable Energy
3. Mr. Prabhakar Singh, Central Public Works Department
4. Mr. Manas Kundu, International Copper Association India
5. Mr. Hemanth, International Copper Association India

27 May 2016 - Delhi

ECBC Update 2016

21

## Number of Meetings conducted for WGs –



27 May 2016 - Delhi

ECBC Update 2016

22

# Technical Committee

27 May 2016 - Delhi

ECBC Update 2016

23

## Government

1. Ministry of New and Renewable Energy (MNRE)
2. Ministry of Urban Development (MOUD/ TCPO/ CPWD)
3. All State Designated Agencies (SDAs)
4. Bureau of Indian Standards (BIS)
5. Central Building Research Institute (CBRI)
6. Building Material and Technology Promotion Council (BMTPC)

27 May 2016 - Delhi

ECBC Update 2016

24

## NGOs

1. GRIHA Council
2. Indian Green Building Council (IGBC)
3. Green Building Council Incorporation - India (GBCI)
4. Centre for Science and Environment (CSE)
5. Alliance to Save Energy (ASE)
6. Natural Resources Defense Council (NRDC)

27 May 2016 - Delhi

ECBC Update 2016

25

## Industry Associations

1. The Indian Institute of Architects (IIA)
2. Builders Association of India (BAI)
3. National Real Estate Development Council (NAREDCO)
4. Indian Building Congress (IBC)
5. Confederation of Indian Industry (CII)
6. Confederation of Real Estate Developers Associations of India (CREDAI)
7. Glazing Society of India (GSI)
8. Indian Insulation Forum (IIF)
9. Indian Glass Manufactures Association

27 May 2016 - Delhi

ECBC Update 2016

26

## Industry Associations

9. Refrigeration and Air-Conditioning Manufacturers Association of India (RAMA)
10. Indian Society of Heating Refrigerating and Air Conditioning (ISHRAE)
11. International Fenestration Forum (IFF)
12. Council of Architects (COA)
13. UPVC Doors and Windows Manufacturer Association (UWDMA)
14. Indian Society of Lighting Engineers (ISLE/ ELCOMA)
15. International Copper Association India (ICAI)

27 May 2016 - Delhi

ECBC Update 2016

27

## Academics and Research

1. Indian Institute of Technology Delhi/ Mumbai / Roorkee
2. Malaviya National Institute of Technology (MNIT)
3. Center for Environmental Planning and Technology (CEPT)
4. Indian institute of Information Technology (IIIT) – Hyderabad
5. Lawrence Berkely National Lab (LBNL)
6. Oak Ridge National Laboratory (ORNL)
7. Pacific Northwest National Lab (PNNL)
8. Devi Ahilya Vishwavidyalaya (hot water and electrical)
9. School of Planning and Architecture (SPA)
10. University School of Architecture and Planning (USAP)

27 May 2016 - Delhi

ECBC Update 2016

28

## Bilateral and Multilateral Agencies

1. Swiss Agency for Development and Cooperation (SDC)
2. French Development Agency - Agence Française de Développement (AFD)
3. Gesellschaft für Internationale Zusammenarbeit (GIZ)
4. Kreditanstalt für Wiederaufbau (KfW)
5. Shakti Sustainable Energy Foundation (SSEF)
6. Indo- EU Building Program
7. United Nations Environment Programme (UNEP)
8. United Nations Development Programme (UNDP)

27 May 2016 - Delhi

ECBC Update 2016

29

## Regional meets



Comments and feedback received in the last three regional consultations has been incorporated into this presentation

30


# ECBC Update Methodology

27 May 2016 - Delhi

ECBC Update 2016

31

## Key Steps





27 May 2016 - Delhi

ECBC Update 2016


32





## Component Approach

In this approach, the stringency of each building material or component is analyzed independently of the rest of the materials, components, and other building specifications



27 May 2016 - Delhi

ECBC Update 2016

35

## Life Cycle Cost Approach

The methodology that considers the Life cycle cost (LCC) of a product, guiding the designers towards qualitative assessment.

- Includes cost like initial investment, maintenance cost, salvage cost etc. in LCC
- Varies with different external factors like climatic zones, building type, usage pattern etc

27 May 2016 - Delhi

ECBC Update 2016

36

## EPI Approach- Bench Marking and Star Rating

The EPI indicates the total energy used in a building every year to the total built up area (air-conditioned or non air-conditioned) and is reported in units of kWh/sq.m/ year

### Need of EPI

- Component approach is conservative and ignores specific opportunities available at different sites
- It also ignores influence of one component, with in a system, over another.

27 May 2016 - Delhi

ECBC Update 2016

37

## Key update priorities concluded in Year 2012

ECBC 2007

### KEY UPDATE PRIORITIES

Concluded based on the consultation meet dated Dec 20, 2012 and feedback received thereafter

Renewable integrations

Easy to understand, implement, and show compliance

Ensure design flexibility and should address loop holes

Comfort systems section to include all key components

Should integrate and promote passive design strategies

Should be developed specific to Indian conditions


Align with the current market scenario and technologies

27 May 2016 - Delhi


ECBC Update 2016



38


## Step 2 – Market assessment



## Baseline objective and scope









## Type 2 - Educational


University Academic Building



Secondary School



Primary School



Lovely University, Noida

27 May 2016 - Delhi



St. Xavier's School, Kolkata

ECBC Update 2016




Tagore Public School, Jaipur


45

## Type 3 - Health Care

Hospital (150+ beds)



Outpatient/ health care



Fortis, Delhi

27 May 2016 - Delhi




Max, Gurgaon  
(upcoming)

ECBC Update 2016


46

## Type 4 - Business


Small office (< 10,000 m<sup>2</sup>)



Medium office (10,000 - 30,000 m<sup>2</sup>)



Large office (>30,000 m<sup>2</sup>)



HCL, Noida

27 May 2016 - Delhi



Tata Power, Noida

ECBC Update 2016




Corporate Tower, Delhi


47

## Type 5 - Commercial Shopping Complex


Shopping Mall



Open Gallery Mall



Strip Retail Shops



Ambience Mall, Delhi

27 May 2016 - Delhi



Cyber Hub, Gurgaon

ECBC Update 2016




Street Retail, Pune

48




## Type 5 (Conti) & Type 6 – Assembly

Super Market (type 5)



Theater (Type 6)



Big Bazaar, Delhi

27 May 2016 - Delhi



PVR, Delhi

ECBC Update 2016

49

## Data collection


Energy Conservation Measures

27 May 2016 - Delhi

ECBC Update 2016

50

## Data collection and collation



27 May 2016 - Delhi

ECBC Update 2016

51

## Energy conservation measures list - wall


- Wall material types
  - Heavy weight wall
    - Brick wall
    - Cement stabilized brick wall
  - Medium weight wall
    - Fly ash brick
    - Hollow concrete block wall
    - AAC block wall
    - Insulated block wall
  - Light weight wall
    - Gypsum board wall
- Construction types
  - Single mass wall
    - with External insulation
    - with internal insulation
  - Cavity Wall
    - external heavy mass
    - internal heavy mass
    - both side heavy mass

27 May 2016 - Delhi

ECBC Update 2016

52


## Mass wall



Material (A)	Thickness (mm)	U value range
Brick	230	<b>Lower Limit:</b> 12 mm plaster, 230 mm brick, 8 mm plaster : <b>2.1 W/m<sup>2</sup> K</b>  <b>Upper Limit:</b> 12 mm plaster, 200 mm AAC block, 8 mm plaster : <b>0.63 W/m<sup>2</sup> K</b>
Cement Stabilized earth block	250, 375	
Fly Ash Brick	200, 300	
Hollow Concrete Block	200, 300	
Insulated Block	200, 300	
Autoclaved Aerated Concrete Block	200, 300	

PACE-D-27, 27 May 2016 - Delhi
ECBC Update 2016
53


## Single mass wall (external insulation)



Material (B)	Thickness (mm)	U value range
Extruded polystyrene (XPS)	25, 50, 75, 100	<b>Lower Limit:</b> 12 mm plaster, 25 mm XPS, 230 mm brick, 8 mm plaster : <b>0.73 W/m<sup>2</sup> K</b>  <b>Upper Limit:</b> 12 mm plaster, 100 mm Polyurethane/ Polyisocyanurate, 200 mm Flyash wall, 8 mm plaster : <b>0.21 W/m<sup>2</sup> K</b>
Expanded polystyrene (thermo Cole) (EPS)	25, 50, 75, 100	
Polyurethane/ Polyisocyanurate	25, 50, 75, 100	

PACE-D-27, 27 May 2016 - Delhi
ECBC Update 2016
54

## Single mass wall (internal insulation)




Material (B)	Thickness (mm)	U value range
Extruded polystyrene (XPS)	25, 50, 75, 100	<b>Lower Limit:</b> 12 mm plaster, 25 mm bonded mineral wool, 230 mm brick, 8 mm plaster : <b>0.81 W/m<sup>2</sup> K</b> <b>Upper Limit:</b> 12 mm plaster, 100 mm Polyurethane/ Polyisocyanurate, 200 mm Fly ash, 8 mm plaster : <b>0.16 W/m<sup>2</sup> K</b>
Expanded polystyrene (thermo Cole) (EPS)	25, 50, 75, 100	
Polyurethane/ Polyisocyanurate	25, 50, 75, 100	
Bonded Mineralwool (Rock/ glasswool)	25, 50, 75, 100	

PAGE-D-77 27 May 2016 - Delhi

ECBC Update 2016

55

## Cavity mass wall




Material (B)	Thickness (mm)	U value range
Extruded polystyrene (XPS)	25, 50, 75, 100	<b>Lower Limit:</b> 12 mm plaster, 230 mm brick, 50 mm Air gap, 115 mm brick, 8 mm plaster : <b>1.22 W/m<sup>2</sup> K</b> <b>Upper Limit:</b> 12 mm plaster, 200 mm AAC block, 100 mm Polyurethane/ Polyisocyanurate, 100 mm AAC block, 8 mm plaster : <b>0.15 W/m<sup>2</sup> K</b>
Expanded polystyrene (thermo Cole) (EPS)	25, 50, 75, 100	
Polyurethane/ Polyisocyanurate	25, 50, 75, 100	
Bonded Mineralwool (Rock/ glasswool)	25, 50, 75, 100	
Air gap	25, 50	

PAGE-D-77 27 May 2016 - Delhi

ECBC Update 2016

56

## Light weight wall




Lower Limit: 12 mm Gypsum Board, 25 mm Mineral wool, 12 mm Gypsum Board : 1.23 W/m<sup>2</sup> K

Upper Limit: 12mm Gypsum Board, 100 mm Polyurethane/ Polyisocyanurate, 12 mm Gypsum Board: 0.19 W/m<sup>2</sup> K

Material (B)	Thickness (mm)	U value range
Extruded polystyrene (XPS)	25, 50, 75, 100	Lower Limit: 12 mm Gypsum Board, 25 mm bonded mineral wool, 12 mm Gypsum Board : 0.96 W/m <sup>2</sup> K
Expanded polystyrene (thermo Cole) (EPS)	25, 50, 75, 100	
Polyurethane/ Polyisocyanurate	25, 50, 75, 100	Upper Limit: 12mm Gypsum Board, 100 mm Polyurethane/ Polyisocyanurate, 12 mm Gypsum Board: 0.22 W/m <sup>2</sup> K
Bonded Mineralwool (Rock/ glasswool)	25, 50, 75, 100	
Air gap	25, 50	

PACE-D 27 May 2016 - Delhi ECBC Update 2016

## Roof (over deck insulation)



Material (C)	Thickness (mm)	
Concrete Slab	150	
Material (D)	Thickness (mm)	U value range
Extruded polystyrene (XPS)	25, 50, 75, 100	Lower Limit: 50 mm brick bat coba, 150 mm concrete slab, waterproofing, 25 mm plaster: 2.51 W/m <sup>2</sup> K
Expanded polystyrene (thermo Cole) (EPS)	25, 50, 75, 100	
Polyurethane/ Polyisocyanurate	25, 50, 75, 100	Upper Limit: 100 mm Polyurethane/ Polyisocyanurate, 150 mm concrete slab, waterproofing, 25 mm plaster: 0.2 W/m <sup>2</sup> K
Brick bat coba	50	
Mud Fuska	75	

PACE-D 27 May 2016 - Delhi ECBC Update 2016

## Roof (under deck insulation)

Material (C)	Thickness (mm)	
Concrete Slab with brick bat coba	200	
Material (D)	Thickness (mm)	U value range
Extruded polystyrene (XPS)	25, 50, 75, 100	<b>Lower Limit:</b> 50 mm brick bat coba, 150 mm concrete slab, waterproofing, 25 mm plaster: <b>2.51 W/m<sup>2</sup> K</b> <b>Upper Limit:</b> 100 mm Polyurethane/ Polyisocyanurate, 150 mm concrete slab, waterproofing, 25 mm plaster: <b>0.19 W/m<sup>2</sup> K</b>
Expanded polystyrene (thermo Cole) (EPS)	25, 50, 75, 100	
Polyurethane/ Polyisocyanurate	25, 50, 75, 100	
Bonded mineral wool	25, 50, 75, 100	


PACE-D-27 May 2016 - Delhi
ECBC Update 2016
59

## Cost analysis for collated data

All cost were reviewed and approved by the Working Groups


27 May 2016 - Delhi
ECBC Update 2016
60

## Milestone 3 – Stringency Analysis



1. Stringency analysis
  - a. Building envelope
  - b. Lighting and Controls
  - c. Comfort Systems and Controls
  - d. Electrical and Renewable

## Building envelope: Scope



## Lighting and Controls - Scope

1. Interior and Exterior lighting requirement
2. Controls
3. Requirement on Luminaire efficiency

27 May 2016 - Delhi

ECBC Update 2016

63

## Comfort Systems and Controls – Scope

- Chillers:
    - Water/ air Cooled
  - Unitary Air-Conditioners :
    - VRF system
    - Single/ Multi Spilt Unit
    - window AC
  - Pumps
    - Chilled-Water Pump
    - Condenser Water Pump
    - Hot water pumps
  - Air Distribution System :
    - AHU and FCUs
    - Fans – Centrifugal/ Axial
  - Cooling towers
  - Boilers
  - System efficiency
  - Controls
  - Natural Ventilation
  - Set points
  - Ducts and pipe insulation
  - Heat recovery and economizers
  - Low energy comfort systems
- New additions are highlighted*

ECBC Update 2016


64



## Electrical and Renewable - scope

- Equipment efficiency and design
  - Transformers
  - Motors
  - Power Factor
  - Electrical Metering and Monitoring
  - Electrical Distribution Systems
  - *Recommended additions –*
    - *Voltage Unbalancing*
    - *Harmonic Distortion*
    - *Size of Neutral Conductors*
    - *Uninterruptible Power Supply*
- Renewable energy
- Hot water
  - a. Solar
  - b. Other hot water equipment

## Milestone 4 – Final recommendations



1. Conduct regional and national workshop (**In process currently**)
2. Address the stakeholder feedback
3. Prepare draft code
4. Public domain comments
5. Conduct Impact analysis

Session 2- Code scope and application

# Administration and Compliance

## Scope

### Sizes of Buildings:



Building complexes with

1. a connected load of 100 KW, or greater or
2. a contract demand of 120 KVA or greater or,

### Exemptions:

*The provisions of this Code do not apply to:*

1. *Equipment and portions of building systems that use energy primarily for manufacturing processes*



## Energy Performance Index – definition recommended for ECBC – *Discussion Point*

EPI shall be kWh/ m<sup>2</sup>/year in terms of purchased & generated electricity divided by built up area in square meter. However the total electricity would not include electricity generated from on-site renewable sources such as solar photovoltaic etc.

Built up area exclude the basement area

27 May 2016 - Delhi

ECBC Update 2016

71

## Precedence

1. Safety, Health, And Environmental Codes.
  - a. Where this Code is found to conflict with safety, health, or environmental codes, the safety, health, or environmental codes shall take precedence.
2. Precedence of BEE's star rating program
3. Precedence of other policy effects like
  1. Refrigerant Phase Out program etc.
  2. Future renewable energy policy developed by MNRE
  3. Norms and Standards of BEE

27 May 2016 - Delhi

ECBC Update 2016

72

## Reference Standards

1. National Building Code (NBC) 2005 is the reference document/ standard for –
  - a. lighting levels,
  - b. HVAC, comfort levels, natural ventilation, pump
  - c. motor efficiencies, transformer efficiencies for sizes not covered in ECBC
  - d. any other building materials and system performance criteria.
  
2. Resolve potential overlap with NBC
  - a. Proactive coordination with NBC Update

## Administration and Enforcement

- Compliance Approach
- Compliance Requirement
- Administration Requirement
- Compliance Documents

## Compliance Approaches

1. Prescriptive Approach
2. Whole building performance (WBP) Approach

Final outcome –

1. Report EPI based on approved tool and design parameters
2. Applicable for both prescriptive and whole building performance approach

27 May 2016 - Delhi

ECBC Update 2016

75

## Compliance requirement

### Applicable buildings

1. Hospitality
2. Educational
3. Health care
4. Assembly
5. Business
6. Commercial Shopping complexes

### Focused climatic zones


1. Temperate
2. Composite
3. Hot and dry
4. Warm and humid
5. Cold

27 May 2016 - Delhi

ECBC Update 2016

76

## Categories based on building use



## Self Occupied

### New Buildings

- Comply with either the prescriptive or Whole building performance requirement

### Additions or alteration to Existing Buildings

- If connected load demand of addition plus the existing building > 100 kW or 120 kVA.

## Core and Shell Buildings

Core and shell buildings where the developer or owner will only provide the base building and its services. Base building will include common areas, circulation areas, parking, basements, services area, and open site area.

Owner/ Developer shall be responsible for demonstrating compliance for core and shell (C&S) buildings



### Building envelope

Renewable energy systems

Electrical systems (installed by developer/ owner)

Comfort systems and controls (installed by developer/ owner)

Lighting systems and controls (installed by developer/ owner)



Legal undertaking that fit out manual for the tenant will have a mandatory requirement of ECBC compliance in interior fit outs

27 May 2016 - Delhi

ECBC Update 2016

79

## Mixed Use Development

Mixed use development may be defined as a single building or a group of buildings housing a combination of residential, commercial, business, educational, hospitality and assembly uses.

If residential is less than 10% of total space, whole building needs to be shown compliance with ECBC. If residential is more than 10%, only non-residential part of the building should comply with ECBC.



*Prescriptive – Each building category portion of the mixed use development to comply with the respective requirement stated in ECBC.*



*Whole building - Area Weighted averages should comply with ECBC EPI requirements.*

27 May 2016 - Delhi

ECBC Update 2016

80



## Enforcement jurisdiction

1. Authority having jurisdiction
  - a. Development Authorities (DA)
  - b. State designated agencies (SDA)
  - c. Municipal Corporations/ ULBs
  - d. Local Bodies
  - e. Utilities


27 May 2016 - Delhi

ECBC Update 2016

81

## ECBC compliance process – Phase 1

First phase of ECBC compliance will be effective for first 5 years of implementation.




27 May 2016 - Delhi

ECBC Update 2016

82

## ECBC compliance process – Phase 2

Second phase of the ECBC compliance will be effective after 5 years of ECBC compliance implementation.



27 May 2016 - Delhi

ECBC Update 2016

83

## Compliance tools

1. Approved software for compliance– ECO-Nirman
2. Approved software for whole building approach
3. Approved tools for showing compliance with prescriptive approach –
  - Approved calculation methodology and tools

27 May 2016 - Delhi

ECBC Update 2016

84

## Penalties

1. Owner's responsibility
2. In case of non-compliance, action could be taken as per the existing laws
3. No construction check will be done in the first phase and till BEE's approved standardized process for construction check is not available.

## Compliance Documents


- Phase 1-
  - Plans and specifications shall show all pertinent data and features of the building, equipment, and systems.
  - Sufficient detail to be provided to permit the Authority Having Jurisdiction to verify that the building complies with the requirements of this code.
- Phase 2-
  - Construction verification compliance documentation

Session 3

# Building Envelope

## Building envelope: Stringency Path

Stringency analysis for wall, glazing, and roof



## Wall (Prescriptive)

	Composite	Hot and dry	Warm & humid	Temperate	Cold
ECBC 2007 8 hours	0.44	0.44	0.44	0.44	0.35
ECBC 2007 24 hours	0.44	0.44	0.44	0.44	0.37
<b>ECBC 2016 Day time</b>	<b>0.40</b>	<b>0.40</b>	<b>0.40</b>	<b>0.55</b>	<b>0.34</b>
<i>Office and school &lt; 10,000 m<sup>2</sup></i>	0.63	0.63	0.63	0.63	0.40
EE building	0.34	0.34	0.34	0.4	0.22
SEE Building	0.22	0.22	0.22	0.22	0.22
<b>ECBC 2016 24 hours</b>	<b>0.40</b>	<b>0.40</b>	<b>0.40</b>	<b>0.40</b>	<b>0.34</b>
EE building	0.34	0.34	0.34	0.34	0.22
SEE Building	0.22	0.22	0.22	0.22	0.22

27 May 2016 - Delhi

ECBC Update 2016

89

## Roof (Mandatory)

	Composite	Hot and dry	Warm & humid	Temperate	Cold
ECBC 2007 8 hours	0.40	0.40	0.40	0.40	0.40
ECBC 2007 24 hours	0.26	0.26	0.26	0.40	0.26
<b>ECBC 2016 Day time</b>	<b>0.30</b>	<b>0.30</b>	<b>0.30</b>	<b>0.30</b>	<b>0.28</b>
<i>School building &lt; 10,000 m<sup>2</sup></i>	0.54	0.54	0.54	0.54	0.30
EE building	0.25	0.25	0.25	0.25	0.20
SEE Building	0.18	0.18	0.18	0.18	0.18
<b>ECBC 2016 24 hours</b>	<b>0.30</b>	<b>0.30</b>	<b>0.30</b>	<b>0.30</b>	<b>0.28</b>
<i>Hospitality buildings</i>	0.19	0.19	0.19	0.30	0.19
EE building	0.20	0.20	0.20	0.20	0.20
SEE Building	0.18	0.18	0.18	0.18	0.18

27 May 2016 - Delhi

ECBC Update 2016

90

## Glazing (Prescriptive)

	Composite	Hot and dry	Warm & humid	Temperate	Cold
<b>WWR</b>	40%	40%	40%	40%	40%
<b>ECBC 2007 standard</b>	U - 3.3 SHGC - 0.25 VLT - 0.2	U - 3.3 SHGC - 0.25 VLT - 0.2	U - 3.3 SHGC - 0.25 VLT - 0.2	U - 6.9 SHGC - 0.40 VLT - 0.2	U - 3.3 SHGC - 0.51 VLT - 0.2
<b>Proposed</b>	U - 3.3 SHGC <sub>non north</sub> - 0.27 SHGC <sub>north</sub> - 0.5 VLT - 0.27	U - 3.3 SHGC <sub>non north</sub> - 0.27 SHGC <sub>north</sub> - 0.5 VLT - 0.27	U - 3.3 SHGC <sub>non north</sub> - 0.27 SHGC <sub>north</sub> - 0.5 VLT - 0.27	U - 3.3 SHGC <sub>non north</sub> - 0.27 SHGC <sub>north</sub> - 0.5 VLT - 0.27	U - 2.8 SHGC <sub>all</sub> - 0.62 VLT - 0.27

**EE and SEE requirement-**

Meet all the proposed requirements of ECBC 2016 and maintain a minimum selectivity ratio of 1.5 for EE buildings and 1.75 for SEE buildings

SHGC<sub>north</sub> of 0.5 is applicable for latitude  $\geq 15^\circ$ , for latitude  $< 15^\circ$ , SHGC<sub>north</sub> to be same as SHGC<sub>non north</sub>

27 May 2016 - Delhi

ECBC Update 2016

U value in  $W/m^2-K$ ,  
SHGC value is maximum limit,  
VLT value is minimum limit

## Discussion points -

1. Naturally ventilated buildings in temperate climatic zone is exempted from the wall insulation requirement
2. Warm & humid climate and insulation water absorption issue

27 May 2016 - Delhi

ECBC Update 2016

92

### SEF table for 28 °N (Prescriptive)

		28 °N											
		Box Frame				Overhang				Fin			
Projection Factor		0.25	0.5	0.75	1	0.25	0.5	0.75	1	0.25	0.5	0.75	1
North		1.25	1.47	1.66	1.81	1.09	1.18	1.25	1.30	1.13	1.22	1.30	1.36
East/ West		1.37	1.85	2.37	3.37	1.21	1.45	1.74	2.06	1.11	1.20	1.27	1.33
South		1.58	2.47	3.62	4.63	1.28	1.59	1.95	2.26	1.18	1.35	1.46	1.55
North-East/ North-West		1.47	1.86	2.25	2.57	1.17	1.35	1.48	1.75	1.21	1.34	1.55	1.69
South-East/ South-West		1.47	2.25	2.90	3.68	1.26	1.60	1.94	2.19	1.14	1.27	1.35	1.44
Example	SHGC	0.25 (say)											
		28 °N											
		Box Frame				Overhang				Fin			
		0.25	0.5	0.75	1	0.25	0.5	0.75	1	0.25	0.5	0.75	1
South		0.39	0.62	0.90	1	0.32	0.40	0.49	0.57	0.29	0.34	0.36	0.39
South-East		0.37	0.56	0.72	0.92	0.31	0.40	0.49	0.55	0.28	0.32	0.34	0.36
South-West		0.35	0.56	0.78	1	0.31	0.38	0.49	0.53	0.29	0.33	0.34	0.36

Similar table for latitude 13 °N is also added in ECBC

### U value requirement for shaded buildings (Prescriptive)

				U value (W/m <sup>2</sup> K)	
		Climate zone	Orientation	SHGC	Shading PF ≥ 0.4
Day time buildings and naturally ventilated buildings		All except cold climate	Non North	0.27	5.0
Rest all categories as per the previous tables					

- Still under the review of Working Group
- Key discussion points
  - ✓ Applicability
  - ✓ Pros and Cons
  - ✓ Comments on the proposed concept

## Daylighting requirement (Mandatory)


Daylighting requirement (manual or simulation)		% above grade area meeting the UDI requirement for 90% of the time in an year
All buildings except*	< 3 storey building (above grade)	40%
	> 3 storey building (above grade)	45%
* Resort	All type	45%
*Shopping malls/ complex	All type	10%

For simulation approach, BEE approved software shall be used


For manual approach, day light extent to be marked/ estimated on the architectural plan to estimate the final percentage area

## Compliance method

### Simulation Approach



### Manual Approach





## Manual approach for daylighting compliance

Day lighting penetration potential – Manual approach for vertical fenestration  
(n X head height, n is as per the table below)

			North	South/ East	West	North	South/ East	West
			VLT < 0.3			VLT ≥ 0.3		
<b>Delhi</b>	<b>All window types</b>	<b>No Shading</b>	<b>1.4</b>	<b>1.0</b>	<b>0.5</b>	<b>1.5</b>	<b>1.1</b>	<b>0.7</b>
<b>Chennai</b>			<b>1.5</b>	<b>1.3</b>	<b>0.6</b>	<b>1.6</b>	<b>1.5</b>	<b>0.8</b>
			Non West		West	Non West		West
			VLT < 0.3			VLT ≥ 0.3		
<b>All latitude types</b>	<b>Vision window</b>	<b>All shading types with PF&gt;0.4</b>	<b>1.5</b>	<b>1.1</b>	<b>1.8</b>	<b>1.5</b>	<b>1.8</b>	<b>1.5</b>
	<b>Clerestorey</b>		<b>1.8</b>	<b>1.6</b>	<b>2.1</b>	<b>1.8</b>	<b>1.8</b>	<b>1.8</b>

27 May 2016 - Delhi

ECBC Update 2016

97


## Key Analysis Results

27 May 2016 - Delhi


ECBC Update 2016

98


## Heavy wall in all climatic zones – Small office (8 hours)




## Glazing performance in all climatic zones - Small office (8 hours)



## Glazing performance in all climatic zones - Small office (8 hours)




## Roof performance in all climatic zones - Small office (8 hours)




## Life Cycle Cost Analysis


27 May 2016 - Delhi ECBC Update 2016 103




## NPV of Savings – Glazing in Composite



## LCC – Glazing in Composite



## LCC and NPV – Glazing in Cold & Cloudy




- a. Corresponding values of SHGC against U value 3 W/m²K is 0.37, 0.46, 0.62.
- b. Considering the importance of solar radiation, 0.62 could be recommended

27 May 2016 - Delhi

ECBC Update 2016

107

## Small office, 8 hours, composite LCC and NPV, Roof



27 May 2016 - Delhi


ECBC Update 2016

108

Analyzing 16 prototypes in 5 climatic zones


## Analysis approach

5 combinations were analyzed based on the weightage to LCC and energy saving potential (ESP)




## Cold and Cloudy – Wall Insulation

Number of buildings prototypes for each U value  
(Cold & Cloudy)



## Composite - wall


Number of Buildings prototypes for each U value  
(Composite)





## Composite - Roof

Number of Buildings prototypes for each U value  
(Composite)



## SHGC values for different orientations

1. The SHGC recommendation of 0.27 for other orientation, except south orientation, could be relaxed.
2. Estimate the trend line equation for each orientation
3. Equate the energy consumption of south orientation with 0.27 SHGC with other orientation, estimate the equivalent SHGC for N/ E/ W orientation

# Shading Analysis


27 May 2016 - Delhi

ECBC Update 2016

115

## Overhangs – (28 °N)

Shading equivalent factor - Overhangs




27 May 2016 - Delhi

ECBC Update 2016

116

## Fins – (28 °N)



## SEF table for 28 °N (Similar for other latitude degrees)

		28 °N											
		Box Frame				Overhang				Fin			
Projection Factor		0.25	0.5	0.75	1	0.25	0.5	0.75	1	0.25	0.5	0.75	1
North		1.25	1.47	1.66	1.81	1.09	1.18	1.25	1.30	1.13	1.22	1.30	1.36
East/ West		1.37	1.85	2.37	3.37	1.21	1.45	1.74	2.06	1.11	1.20	1.27	1.33
South		1.58	2.47	3.62	4.63	1.28	1.59	1.95	2.26	1.18	1.35	1.46	1.55
North-East/ North-West		1.47	1.86	2.25	2.57	1.17	1.35	1.48	1.75	1.21	1.34	1.55	1.69
South-East/ South-West		1.47	2.25	2.90	3.68	1.26	1.60	1.94	2.19	1.14	1.27	1.35	1.44
Example	SHGC	0.25 (say)											
		28 °N											
		Box Frame				Overhang				Fin			
		0.25	0.5	0.75	1	0.25	0.5	0.75	1	0.25	0.5	0.75	1
South		0.39	0.62	0.90	1	0.32	0.40	0.49	0.57	0.29	0.34	0.36	0.39
South-East		0.37	0.56	0.72	0.92	0.31	0.40	0.49	0.55	0.28	0.32	0.34	0.36
South-West		0.35	0.56	0.78	1	0.31	0.38	0.49	0.53	0.29	0.33	0.34	0.36

Similar table for latitude 13 °N will be added

## U value exemption for shaded buildings


				U value (W/m <sup>2</sup> K)
	Climate zone	Orientation	SHGC	Shading PF ≥ 0.4
Day time buildings and naturally ventilated buildings	All except cold climate	Non North	0.27	5.0

27 May 2016 - Delhi

ECBC Update 2016

119

## Thermal energy variation with different glazing combination



27 May 2016 - Delhi

ECBC Update 2016

120

# Day lighting Analysis

27 May 2016 - Delhi ECBC Update 2016 121

## Day lighting Requirement

### Daylighting Analysis

```
graph LR; Concept[Concept] --> Parameters[Guiding Parameters]; Parameters --> Simulations[Simulations]
```

**Concept**

- Useful Daylighting Index
- Manual and simulation compliance format
- Ease to show and check compliance

**Guiding Parameters**

- Glare
- Visual light transmittance
- Latitude angle
- Orientations
- Window types
- Ease of compliance

**Simulations**

- 220 simulations were done for one set of results

27 May 2016 - Delhi ECBC Update 2016 122

## Useful Daylight Illuminance (UDI)

1. UDI metric bins hourly time values based upon three illumination ranges, 0-100 lux, 100-2000 lux, and over 2000 lux. It provides full credit only to values between 100 lux and 2,000 lux for at least 90% of the time.
2. 220 simulations were done to document the extent possible with different façade combinations in each orientation for 2 latitudes. The results for useful daylight extent for south orientation in Chennai is shown in next few slides


27 May 2016 - Delhi

ECBC Update 2016

123

## Case 2 – Vision window - No shading and VLT > 0.3

Analysis Grid  
Annual Illuminance  
Value Range: 0 - 100 %  
© 2012 ECBC



27 May 2016 - Delhi

ECBC Update 2016

124

## Manual approach for daylighting compliance

Day lighting penetration potential - manual for vertical fenestration  
(n X head height, n is as per the table)


			North	South/ East	West	North	South/ East	West
Window type Shading			VLT < 0.3			VLT ≥ 0.3		
Delhi	All window types	No Shading	1.4	1.0	0.5	1.5	1.2	0.8
Chennai			1.5	1.3	0.6	1.6	1.5	1.0
window type Shading			Non West	West	Non West	West		
			VLT < 0.3		VLT ≥ 0.3			
All latitude types	Vision window	All shading types with PF>0.4	1.5	1.1	1.8	1.5		
	Clerestorey		1.8	1.6	2.1	1.8		

27 May 2016 - Delhi

ECBC Update 2016

125



## Manual Compliance Method - Floor Plan





27 May 2016 - Delhi

ECBC Update 2016

126







## Cool roof

27 May 2016 - Delhi

ECBC Update 2016

131

### Cool roof (Mandatory)

1. Roofs with slopes less than 20 degrees shall have an initial solar reflectance of no less than 0.7 and an initial emittance no less than 0.75.
2. Solar reflectance shall be determined in accordance with ASTM E903-96 and emittance shall be determined in accordance with ASTM E408-71 (RA 1996).

27 May 2016 - Delhi

ECBC Update 2016

132

Session 4

# Lighting and Controls

## Lighting and Controls - Process

150 products under  
5 lamps categories –  
LEDs, T5, T8, CFL, T12.

8 controls types

Details like lamp  
wattage, efficacies,  
utilization factor



tables cost

100 spaces for space  
by space method

16 building  
prototypes for  
building are method

500+ LPDs based on  
different spaces and  
lamp categories

Undertaken techno-  
economic analysis



## Key findings from data collation survey

4. Increased cost of energy efficient fixture could be compensated with increased efficacy of the fixture
5. ECBC 2007 LPD values are easily achieved with any fixture with an efficacy of 45 - 60 lm/ Watt (T12 or T8)
  - 50 % of space LPD listed in ECBC 2007 could be met with T12, and additional 30% could be met with T8

27 May 2016 - Delhi

ECBC Update 2016

137

## LCC Estimation for each lamp type


Recommendations		L3 - CFL								
Recommendations	CFL			L3 - CFL						
	Total cost (Rs/m <sup>2</sup> )	LPD (W/m <sup>2</sup> )	Annual Energy used (9 hours) (kWh/m <sup>2</sup> )	Savings above baseline (kwh/m <sup>2</sup> )	Money saved every year	Add. cost (Rs/m <sup>2</sup> )	Cost to save per unit	Simple pay back (yrs)	NPV of savings (Rs./m <sup>2</sup> )	
<b>Office</b>										
Enclosed	51.45	15.3	32.06	-5.51	-56.76	35	-6.30	-0.61	-260	
Open Plan	51.45	15.3	32.06	-5.51	-56.76	35	-6.30	-0.61	-260	
Restrooms	19.29	5.7	12.02	9.80	101.08	11	1.12	0.11	463	
Stairway	18.37	5.5	11.45	3.18	32.75	9	2.88	0.28	150	
Storage	22.97	6.8	14.31	5.04	51.96	16	3.09	0.30	238	
Workshop	73.50	21.9	45.79	0.33	3.42	56	168.49	16.34	16	
Service/Repair	22.97	6.8	14.31	2.56	26.44	12	4.80	0.47	121	
<b>Bank/Office</b>										
Banking Activity Area	61.25	18.2	38.16	-1.94	-19.96	47	-24.49	-2.38	-91	
<b>Convention Center</b>										
Audience Seating	22.97	6.8	14.31	2.56	26.44	12	4.80	0.47	121	
Exhibit Space	45.93	13.7	28.62	2.88	29.68	-1	-0.36	-0.03	136	

27 May 2016 - Delhi



ECBC Update 2016


138

## Offices – building area method (W/m<sup>2</sup>)

Office					
<b>Built up Area (m<sup>2</sup>)</b>	20,000				
<b>Form</b>	Rectangle				
<b>Aspect Ratio</b>	1.8				
<b>Number of Floors</b>	3				
<b>Number of Basement</b>	2				
					
<b>Space Distribution (%)</b>		ECBC 2007	ECBC 2016	EE Buildings	SEE buildings
Office Space	80		10.0		
Circulation	5		7.1		
Reception and Lobby	5		9.1		
Services	10		6.8		
<b>Total</b>	<b>100</b>	<b>10.8</b>	<b>9.5</b>	<b>7.6</b>	<b>5.0</b>
<b>Percentage reduction</b>			<b>12.1%</b>	29.5%	53.1%

## Lighting: Life Cycle Cost Analysis





## Key observations

1. Additional cost of switching to EE fixture is marginal for T5 fixture and CFL w.r.t baseline. LEDs are expensive.
2. Cost of light installation based on lighting design for a T5 and CFL are almost same.
3. Cost of T5 are 25% higher compared to CFL, the utilization factor of T5 are 22% less than CFL



## Key observations

4. Money saved annually due to reduced energy consumption is nearly 3 to 4 times.
5. NPV of the energy saved during the life period of a fixture is 5 - 8 times the total fixture cost based on per unit fixture requirement making the up gradation very lucrative.
6. The simple payback of all EE fixtures is less than a year.

## ECBC 2016 Recommendations

## Light Power Density requirement – Approach (Mandatory – Discussion Point)

1. LPD estimate for space by space method
  - a. Key spaces in a buildings more efficient than supporting areas
  - b. Requirement for EE buildings and SEE buildings are 20% and 50% more efficient than ECBC requirement respectively
2. LPD estimate for Building area method
  - a. The proportional average LPD for the whole building was estimated based on the proportional distribution of space and the estimated prescribed LPD values in space function stringency analysis

27 May 2016 - Delhi

ECBC Update 2016

147

## LPD recommendations for Building area method

LPD comparison as per whole building area method (W/m <sup>2</sup> )					
	ECBC 2007	ECBC 2016	% reduction	EE Building	SEE Building
Office Building	10.8	9.5	12.1%	7.6	5.0
Hospitals	12.9	9.7	25%	7.8	4.9
Hotels	10.8	9.5	12%	7.6	4.8
Shopping Mall	16.1	14.1	12.5%	11.3	7.0
University and Schools	12.9	11.2	13%	9.0	6.0
Library	14	12.2	13%	9.8	6.1
Dining: bar lounge/leisure	14	12.2	13%	9.8	6.1
Dining: cafeteria/fast food	15.1	11.5	24%	9.2	5.8
Dining: family	17.2	10.9	37%	8.7	5.5
Dormitory	10.8	9.1	16%	7.3	4.6
Fire station	10.8	9.7	10%	7.8	4.9
Gymnasium	11.8	10	15%	8.0	5.0
Manufacturing facility	14	12	14%	9.6	6.0

27 May 2016 - Delhi

ECBC Update 2016

148

## LPD recommendations for Building area method

LPD comparison as per whole building area method (W/m <sup>2</sup> )						
	ECBC 2007	ECBC 2016	% reduction	EE Building	SEE Building	ASHRAE 90.1 – 10
Motion picture theater	12.9	<b>9.43</b>	27%	7.5	4.7	8.9
Museum	11.8	<b>10.2</b>	14%	8.2	5.1	17.2
Post office	11.8	<b>10.5</b>	11%	8.4	5.3	9.4
Religious building	14	<b>12</b>	14%	9.6	6.0	10.8
Sports arena	11.8	<b>9.7</b>	18%	7.8	4.9	8.4
Transportation	10.8	<b>9.2</b>	15%	7.4	4.6	8.3
Warehouse	8.6	<b>7.08</b>	18%	5.7	3.5	7.1
Performing arts theater	17.2	<b>16.3</b>	5%	13.0	8.2	15.0
Police station	10.8	<b>9.9</b>	8%	7.9	5.0	10.3
Workshop	15.1	<b>14.1</b>	7%	11.3	7.1	12.9
Automotive facility	9.7	<b>9</b>	7%	7.2	4.5	8.8
Convention center	12.9	<b>12.5</b>	3%	10.0	6.3	19.4
Parking garage	3.2	<b>3</b>	6%	2.4	1.5	2.7

27 May 2016 - Delhi

ECBC Update 2016

149

## Offices – space by space method (W/m<sup>2</sup>)

Lamp category	NBC standard	NBC Lux (Avg)	ASHRAE E (lux)	ASHRAE 2010-13	ECBC 2007	ECBC 2016	% reduction	EE buildings (20% efficient)	SEE buildings (50% efficient)
Enclosed	300-500-750	<b>400</b>	400	11.9	11.8	<b>10.0</b>	15%	8.6	5.4
Open Plan	300-500-750	<b>400</b>	400	10.5	11.8	<b>10.0</b>	15%	8.6	5.4
Banking Activity Area	300-500-750	<b>400</b>	400	14.8	16.1	<b>12.6</b>	22%	9.3	5.8
Conference/Meeting	200-300-500	<b>300</b>	<b>400</b>	13.2	14.0	<b>11.5</b>	18%	9.2	5.7
For Elevator	150-200-300	200	215	6.9		<b>9.1</b>	N/A	7.3	4.6
Corridor/Transition	<b>70-150</b>	100	50	7.1	5.4	<b>7.1</b>	N/A	3.6	2.3
Restrooms	100-150-200	<b>200</b>	<b>300</b>	10.5	9.7	<b>7.7</b>	21%	6.1	3.8
Stairway	50-100-150	<b>100</b>	<b>50</b>	7.4	6.5	<b>5.5</b>	16%	4.4	2.7
Storage	50-100-150	100	100	6.8	8.6	<b>6.8</b>	21%	5.4	3.4
Electrical/Mechanical	50-100-150	<b>100</b>	<b>215</b>	10.2	10.1	<b>7.1</b>	30%	5.7	3.5
Workshop	200-300-500	<b>400</b>	400	17.1	20.5	<b>17.1</b>	17%	13.7	8.6
Service/Repair	100-150-200	<b>150</b>	<b>200</b>	7.2	7.5	<b>6.8</b>	9%	5.5	3.4

With similar approach, more than 150 spaces will be listed

27 May 2016 - Delhi

ECBC Update 2016

150

# Controls

27 May 2016 - Delhi

ECBC Update 2016

151

## Controls scope in ECBC 2016 (Mandatory)

### Space controls

- Independent controls for
  - Max 250m<sup>2</sup> if space <1000m<sup>2</sup>
  - Max 1000m<sup>2</sup> if space >1000m<sup>2</sup>
- Override the shutoff control for max 2 hours
- Readily accessible

Mandatory for buildings >  
20,000 sqm – **discussion point**

### Automatic Lighting Shutoff

- Automatic control devises for Office spaces > 300 m<sup>2</sup>
    - Schedule based, for max 2500 m<sup>2</sup> and one floor
  - Spaces > 25 m<sup>2</sup> – Occupancy
    - Conference rooms
    - Classrooms, laboratories
    - Storage spaces > 15 m<sup>2</sup>
    - Hotel public toilets >25 m<sup>2</sup>
    - Hotel and hospital corridors
- Turns off within 15 mins, for only 95% light of the space

ECBC Update 2016

152

## Controls scope in ECBC 2016 (Mandatory for all buildings)

### Exterior lighting controls

- Mandatory daylight sensor or time switch
  - For all universities, IT campus, and buildings with a BUA > 15,000 m<sup>2</sup>
    - avg light source efficacy of not less than 70 lumens/W
    - All landscaping lighting should have an installed motion detector for 80% of the landscaping and street lighting (on/off or 50% dimmable)
  - Façade lighting or signage have separate time switch
- exceptions - emergency lighting,

### Daylighting controls

- all corridors, lobby, and toilets
- manual or automatic control within 5 meters of a window
  - switch level set point adjusted btw 50 to 1000 lux
  - delay of >2 mins, and differential > than 50 lux
  - dimmed or stepped to 50% of total power
  - Over rides to daylighting sensor should not be allowed
- **Incentive** - LPD adjustment factor of 20% is applicable, within the daylight zone, to any spaces if > 70% of space is having daylight controls

27 May 2016 - Delhi

ECBC Update 2016

153

## EE and SEE buildings – controls requirement

1. Mandatory requirement of centralized system of lighting controls
  - a. Schedule based operation
  - b. Day light sensor controls
  - c. Dimmable controls (manual or automatic)

27 May 2016 - Delhi

ECBC Update 2016

154

## Luminaire wattage

- a. Luminaire efficacy should be 0.7 or above
- b. If luminaire has a permanently installed ballast, the considered wattage of the system shall be the operating input wattage of overall system based on the manufacturer or laboratories
- c. If luminaire doesn't not have a permanently installed ballast, the considered wattage of the system shall be maximum labeled wattage of the luminaire
- d. Considered wattage of all other luminaire types shall be the specified wattage of the luminaire

27 May 2016 - Delhi

ECBC Update 2016

155

## Exterior lighting (Mandatory)

Exterior lighting application	Power Limits
Building entrance (with canopy)	10 W/m <sup>2</sup> of canopied area
Building entrance (w/o canopy)	90 W/ linear m of door width
Buiding exit	60 W/lin m of door width
Building façade	5 W/m <sup>2</sup> of vertical façade area
Emergency signs, ATM kiosks, Security areas façade	1 W/m <sup>2</sup>
Parking areas (covered/ basement)	2.2 W/m <sup>2</sup>
Driveways (covered/ basement)	3 W/m <sup>2</sup>
Driveways and parking (open/ external)	1.6 W/m <sup>2</sup>
Pedestrian walkways	2.0 W/m <sup>2</sup>
Stairways	10.0 W/m <sup>2</sup>
Landscaping	0.5 W/m <sup>2</sup>
Outdoor sales area	9.0 W/m <sup>2</sup>

Recommended value for EE and SEE buildings are 20% and 50% efficient to the ECBC 2016 recommendation

ECBC Update 2016

156

## Session 4

# Comfort systems and Controls

## Key Highlights

### Wider Scope

Additional equipment, Thermal comfort, and Ventilation

### Ease of Compliance check

Concept of W/ ton was introduced in Fans, Pumps and Cooling towers

### System Efficiency

System efficiency ensures design flexibility and innovation

### Advance controls requirement

Wider scope of controls requirement, specific to space and building

### Low Energy Comfort System and Natural Ventilation

ECBC 2016 to include compliance path for low energy comfort systems as well as Natural Ventilations

### Technology Independent Requirement

Recommendation for chillers are technology independent

## Comfort Systems and Controls – revised Scope

- Chillers:
  - Water/ air Cooled
- Unitary Air-Conditioners :
  - VRF system
  - Single/ Multi Spilt Unit
  - window AC
- Pumps
  - Chilled-Water Pump
  - Condenser Water Pump
  - Hot water pumps
- Air Distribution System :
  - AHU and FCUs
  - Fans – Centrifugal/ Axial
- Cooling towers
- Boilers
- System efficiency
- Controls
- Natural Ventilation
- Set points
- Ducts and pipe insulation
- Heat recovery and economizers
- Low energy comfort systems

27 May 2016 - Delhi

ECBC Update 2016

159

## Set points

Based on the study done by CEPT University

27 May 2016 - Delhi

ECBC Update 2016

160



## Natural Ventilated building

$$\text{Indoor Operative Temperature} = (0.54 \times \text{outdoor temperature}) + 12.83$$

- Where, indoor operative temperature (°C) is neutral temperature, & outdoor temperature is the 30-day outdoor running mean air temperature (°C).
- The 90 percent acceptability range for the India specific adaptive models for naturally ventilated buildings is  $\pm 2.38^{\circ}\text{C}$ .

$$\text{Delhi: Indoor Operative Temperature} = (0.54 \times 33.0) + 12.83 = \underline{30.68^{\circ}\text{C}}$$

## Mixed mode building

$$\text{Indoor Operative Temperature} = (0.28 \times \text{outdoor temperature}) + 17.87$$

- Where indoor operative temperature (°C) is neutral temperature & outdoor temperature is the 30-day outdoor running mean air temperature (°C).
- The 90 percent acceptability range for the India specific adaptive models for mixed-mode buildings is  $\pm 3.46^{\circ}\text{C}$ .

$$\text{Delhi: Indoor Operative Temperature} = (0.28 \times 33.0) + 17.87 = \underline{27.1^{\circ}\text{C}}$$

## Air-conditioned building

### 1. Air temperature based approach:

$$\text{Indoor Operative Temperature} = (0.078 \times \text{outdoor temperature}) + 23.25$$

- Where indoor operative temperature (°C) is neutral temperature & outdoor temperature is the 30-day outdoor running mean air temperature (°C).
- The 90 percent acceptability range for the adaptive models for conditioned buildings is  $\pm 1.5^\circ\text{C}$ .

$$\text{Delhi: Indoor Operative Temperature} = (0.078 \times 33.0) + 23.25 = \underline{25.8^\circ\text{C}}$$

## Air-conditioned building

### 2. Standard Effective Temperature Based Approach:

$$\text{Indoor Operative Temperature} = (0.014 \times \text{outdoor temperature}) + 24.53$$

- Where indoor operative temperature (°C) is neutral temperature & outdoor temperature is the 30-day outdoor running mean air temperature (°C).
- The 90 percent acceptability range for the adaptive models for conditioned buildings is  $\pm 1.0^\circ\text{C}$ .

$$\text{Delhi: Indoor Operative Temperature} = (0.014 \times 33.0) + 24.53 = \underline{24.99^\circ\text{C}}$$

Note: Above equations are not applicable for outdoor running mean temperatures below  $15^\circ\text{C}$ .

# Chillers


(Mandatory – Discussion point)

27 May 2016 - Delhi

ECBC Update 2016

165

## Chiller: Process of recommendations



27 May 2016 - Delhi

ECBC Update 2016

166

## Chillers – ECBC 2016 Recommendation: Option 1

	Equipment Class	ECBC 2016 (MEPs.)		EE	SEE
		Constant	VSD	COP	COP
Air Cooled Chiller	<530 kW (<150 TR)	3.0	2.7	3.3	NA
	≥530 kW (≥150 TR)	3.0	2.7	3.3	NA
Water cooled chiller	<530 kW (<150 TR)	5.5	5.0	5.8	6.1
	≥530 & <1050 kW (≥150 and <300 TR)	5.8	5.2	6.1	6.3
	≥1050kW (≥ 300 TR)	6.1 (5.8)	5.5	6.3	6.5
	≥2110 kW (≥ 600 TR)	6.3	5.7	6.5	6.7

### Discussion on relaxed COP for Distributed chiller systems ?

- ❑ The values in small brackets () in water cooled chillers are screw chiller COPs for reference only.
- ❑ The COP of VSD compressor based chiller are 10% less of fixed speed chiller COP.
- ❑ Number of Air-cooled chiller can be restricted.

27 May 2016 - Delhi

ECBC Update 2016

167

## Chillers – ECBC 2016 Recommendation: Option 2

	Equipment Class	ECBC 2016 (MEPs)	EE building	SEE building
		COP	COP	COP
Air Cooled Chiller with condenser electrical	<530 kW (<150 TR)	<b>3.0</b>	3.3	NA
	≥530 kW (≥150 TR)	<b>3.0</b>	3.3	NA
Centrifugal Water Cooled	< 530 kW (<150 TR)	<b>5.0</b>	5.6	5.68
Centrifugal Water Cooled	≥530 & <1050 kW (≥150 and <300 TR)	<b>5.55</b>	5.8	6.23
Centrifugal Water Cooled chillers	≥1050kW (≥ 300 TR)	<b>6.1</b>	6.3	6.48
<i>water cooled centrifugal</i>	≥2100 kW ≥ 600 TR	<b>6.2</b>	6.5	6.7
Reciprocating Compressor, Water Cooled Chiller	all sizes	<b>4.2</b>	4.7	5.4
Rotary Screw and Scroll Compressor, Water Cooled	<530 kW (<150 TR)	<b>4.7</b>	5.0	5.8
Rotary Screw and Scroll Compressor, Water Cooled	≥530 & <1050 kW (≥150 and <300 TR)	<b>5.4</b>	5.5	6.3
Rotary Screw and Scroll Compressor, Water Cooled	≥ 1050 kW (≥ 300 TR)	<b>5.75</b>	6.0	6.45

27 May 2016 - Delhi

ECBC Update 2016

168


# Air Systems

27 May 2016 - Delhi

ECBC Update 2016

169

## Air-System (Fans) - Process



27 May 2016 - Delhi

ECBC Update 2016

170

## Fans – recommendations (Prescriptive)


Fan efficiencies							
System type	Fan Type	Mechanical Efficiency			Motor Efficiency		
		ECBC	EE	SEE	ECBC	EE	SEE
Central system / Duct able VRVs	Supply	60%	65%	70%	IE 2	IE 3	IE 4
	Return and Exhaust	55%	60%	65%	IE 2	IE 3	IE 4

Fan efficiency requirement applicable to motor power exceeding 0.37 kW.

**Discussion point** - different efficiency for supply & return fans recommended?

## Pumps

## Pump energy efficiency - Process



## Pumps – recommendations (Prescriptive)

ECBC 2016 - installed pump capacity (Watt) per Installed cooling capacity at a building level chilled water system

System type	ECBC 2016	EE building	SEE building
Chilled water Pump (P + S)	18.2 W/ kW <sub>r</sub> (64 W/ ton <sub>r</sub> ) with VSD	16.9 W/ kW <sub>r</sub> (59.5 W/ ton <sub>r</sub> ) with VSD	14.9 W/ kW <sub>r</sub> (52.5 W/ ton <sub>r</sub> ) with VSD
Condenser water pump	17.7 W/ kW <sub>r</sub> (62.3 W/ ton <sub>r</sub> )	16.5 W/ kW <sub>r</sub> (58.1 W/ ton <sub>r</sub> )	14.6 W/ kW <sub>r</sub> (51.2 W/ ton <sub>r</sub> )
	With 70% efficiency	With 75% efficiency	With 85% efficient pumps

Pumps requirements for district chiller system is limited to the installed efficiency requirement of individual pump equipment only

## Cooling towers (Prescriptive)

Equipment type	Rating Condition	ECBC 2016
Propeller or axial fan open/ closed -circuit cooling towers	95°F/ 35°C entering water 85°F/ 29°C leaving water 75°F/ 24°C wb outdoor air	0.017 kW/kW <sub>r</sub> (0.062 kW/ton <sub>c</sub> ) 0.31 kW/ L/s (≥38.2 gpm/ hp)
Centrifugal fan open/ closed -circuit cooling towers	95°F/ 35°C entering water 85°F/ 29°C leaving water 75°F/ 24°C wb outdoor air	0.034 kW/kW <sub>r</sub> (0.12 kW/ton <sub>c</sub> ) (0.59 kW/ L/s ) ≥20.0 gpm/ hp

Assumption - 3.2 gpm/ ton  
Tonnage considered for analysis is the cooling capacity  
EE buildings and SEE buildings to have additional controls requirements

27 May 2016 - Delhi

ECBC Update 2016

175

## Boilers (Prescriptive)

Equipment type	Sub category	Size category	Minimum efficiency
Boilers, hot water	Gas fired	<88 kW	80% AFUE
		≥88 kW and ≤732 kW	75% Et
		>732 kW	80% Ec
	Oil fired	<88 kW	80% AFUE
		≥88 kW and ≤732 kW	78% Et
		>732 kW	83 % Ec

AFUE - annual fuel utilization efficiency  
Ec - combustion efficiency (100% less flue losses)  
Et - Thermal efficiency

27 May 2016 - Delhi

ECBC Update 2016

176



## Unitary and Split Air conditioners (Mandatory)

1. All the window AC and split AC less than 3 TR (10.5 kW<sub>e</sub>) of cooling and/ or heating capacity will be as per BEE star rated programs
2. ECBC 2016 recommendation level
  - Minimum performance building – 3 star labelled (as for commercial use)
  - Energy efficient (EE) building – 4 star labelled
  - Super EE building – 5 star labelled

27 May 2016 - Delhi

ECBC Update 2016

177

## Unitary, Split and Packaged Air conditioners

Cooling Capacity			ECBC 2007 - COP		ECBC 2016		EE Buildings		SEE Buildings	
Watts	TR of Refri	kWr	Water Cooled	Air Cooled	Water Cooled	Air Cooled	Water Cooled	Air Cooled	Water Cooled	Air Cooled
≤10,500	≤ 3	≤ 10.5	NA	NA	NA	BEE 3 Star	NA	BEE 4 Star	NA	BEE 5 Star
> 10,500	> 3	>10.5	2.67	2.11	3.55	3.28				
17,500	5	17.5	2.92	2.50	3.55	3.28				
26,250	7.5	26.25	2.92	2.63	3.55	3.28				
35,000	10	35	3.04	2.59	3.55	3.28				
52,000	15	52.5	3.06	2.60	3.55	3.28				

27 May 2016 - Delhi

ECBC Update 2016

178

## Variable Refrigerant Flow Air Conditioner (Mandatory)

1. BEE is under process to develop the test standards on VRF based on Indian conditions
2. ECBC 2016 will refer to the conclusions of this study for mandatory requirements
3. Until the study is under process, ASHRAE 90.1 2010's COP levels for VRF will be referred for all analysis

27 May 2016 - Delhi

ECBC Update 2016

179

## Variable Refrigerant Flow Air Conditioner– ASHRAE 90.1 2010

Equipment type	Size category	Minimum Efficiency (2010)
VRF Air Conditioners, Air cooled	<19 kW	3.28 COP
	>=19 kW and < 40 kW	3.29 COP
	>= 40 kW and < 70 kW	3.26 COP
	>= 70 kW	3.02 COP

- BEE is under process to develop the test standards on VRF based on Indian conditions
- ECBC 2016 will refer to the conclusions of this study for mandatory requirements
- Until the study is under process, ASHRAE 90.1 2010's COP levels for VRF will be referred for all analysis

27 May 2016 - Delhi

ECBC Update 2016

180

## Precision Air Conditioner units

(Mandatory - Applicable to buildings with BUA > 20,000 sqm)

Equipment type	Net Sensible Cooling Capacity <sup>a</sup>	Minimum SCOP-127 <sup>b</sup>	
		Downflow	Upflow
Air Conditioners, Air cooled	<19 kW	2.20	2.09
	>=19 kW and < 70 kW	2.10	1.99
	>=70 kW	1.90	1.79
Air Conditioners, Water cooled	<19 kW	2.60	2.49
	>=19 kW and < 70 kW	2.50	2.39
	>=70 kW	2.40	2.29

- a. Net Sensible cooling capacity = Total gross cooling capacity - latent cooling capacity - Fan power  
 b. Sensible coefficient of performance (SCOP-127): A ratio calculated by dividing the net sensible cooling capacity in watts by the total power input in watts (excluding reheater and dehumidifier) at conditioned defined in ASHRAE standard 127)

This is under the review of WG meeting

**Discussion points** - comments on inclusion of the it in the code

03 Feb 2016 - Bengaluru

ECBC Update 2016

181

## System efficiency

27 May 2016 - Delhi

ECBC Update 2016

182

## Methodology to compute the system efficiency – ECBC 2016

Estimate the peak cooling demand for different building type, climate zone and size using energy simulation

Considered major components under chilled water plant i.e. chiller, chilled water and condenser water pump

Assumption are made as per Indian perspective (NBC/ ECBC 2016 recommendations) and surveys

Determine electrical power at Full load conditions of each components

## System efficiency for building cooling system (Prescriptive)

Minimum system efficiency (total installed equipment per cooling capacity kW/ kW<sub>r</sub>)

System type	Peak building cooling load (kW)	
	<3516 kW (1,000 TR)	≥ 3516 kW (1,000 TR)
Central chilled water plant (Water cooled)	0.21 (0.75 kW/ ton <sub>r</sub> )	0.20 (0.70 kW/ ton <sub>r</sub> )

- Central water plant includes chillers, chilled water and condenser water pumps and cooling tower.
- Values of EE building and super EE buildings will be derived based on the finalized ECBC 2016 recommendations

## System balancing (Mandatory)

- a. Requires written balance report for a HVAC system if total conditioned area exceeding 500 m<sup>2</sup>

Discussion point - Written balancing report for HVAC system by 3rd party should be required if total conditioned area exceeding 5000 m<sup>2</sup>

- a. Air system balancing
  - To first minimize throttling losses
  - If fan system power is greater than 0.75 kW, fan speed shall be adjusted to meet design flow conditions
- b. Hydronic system balancing
  - To first minimize throttling losses
  - Trim pump impeller or adjust pump speed to meet design flow conditions

(if pump motor < 7.5 kW) ECBC Update 2016

185

## Economizer

27 May 2016 - Delhi

ECBC Update 2016

186

## Economizer

Applicable on Air side economizer if

- a. A design supply capacity over 1,200 l/s (2,500 cfm); and
- b. A total mechanical cooling capacity over **15.8 kW**

Exceptions to above are:

- a. *Projects in the warm-humid climate*
- b. *Day time use in hot & dry*
- c. *Individual ceiling mounted fan < 3,200 l/s (6,500 cfm)*

## Heat recovery

## Heat Recovery scope

1. Air to air heat recovery –
  - a. 70% recovery effectiveness for all systems greater than 2100 l/s and minimum outdoor air supply of 70%.
2. Heat recovery from Diesel or gas fired Generator sets
  - a. Minimum 50% heat recovery from DG sets in all hotels and office buildings having area greater than 20,000 m<sup>2</sup>

## Controls

## Controls – recommendations (as per market trend)

- Time switches/ Off hour / automatic setback, start, shut-off controls
- Temp/ Set point/ humidity control
- Occupancy control
- VAV controls
- Automatic damper control
- Automatic demand shed controls
- Economizer fault detection control

27 May 2016 - Delhi

ECBC Update 2016

191

## Time clock that (Mandatory)

- a. Mandatory for all offices and malls above 15,000 m<sup>2</sup>
- b. Mandatory for all Universities
  - Automatically start and stop (different schedules)
  - Retain programming and time setting
  - Accessible manual override
    - a. Exceptions to the above are:
      - » a. Cooling systems < 17.5 kW (5 TR)
      - » b. Heating systems < 5 kW (1.4 TR)

27 May 2016 - Delhi

ECBC Update 2016

192



## Temperature Control (mandatory)

- a. Mandatory for all day time offices and malls above 20,000 m<sup>2</sup>
  - temperature dead band of 3°C (5°F)
  - For warm and humid climate zone, should maintain the humidity less than 60%
  - Mandatory thermostat setting control for all guest rooms of a hotel/ motel
  - Mandatory for rooms size < 25 sqm

## Controls

- ✓ **Cooling Towers and Closed Circuit Fluid Coolers (Mandatory)**
  - Mandatory for building more than 20,000 m<sup>2</sup> of BUA
  - Should have either two speed motors, pony motors, or variable speed drives controlling the fans.
  - Should be capable to reduce the fan speed to at least two third of installed fan power
- ✓ **Dampers for Air Supply and Exhaust Equipment (Mandatory)**
  - dampers that automatically close upon fan shutdown or spaces served are not in use.

## Occupancy control (mandatory)

### ✓ Occupancy control (mandatory)

- De-energized the system when no occupants for following:
  - **Hotel guest room**
  - **Toilets in hotels** and offices with more than 2 WCs and/ or 3 urinals
  - **Conference and meeting rooms in offices**
  - **Any room in a school or university which is more than 80 m<sup>2</sup>**

27 May 2016 - Delhi

ECBC Update 2016

195

## Automatic Demand Shed Controls (EE & SEE building)

- a. Applicable for HVAC systems with DDC to the Zone level for non critical zones
- b. remotely setup the operating temp set points by 4 degrees by centralized program
- c. programmed to provide an adjustable rate of change for the temperature setup and reset
- d. The controls shall have features like - Disabled, Manual Control, Automatic Demand shed control
- e. 20,000 sqm slab for BMS requirement – basic – controls and air handlers

27 May 2016 - Delhi

ECBC Update 2016

196

## Supply Air Temperature Reset (EE & SEE)

1. Multi-zone HVAC systems must include controls that automatically reset the supply-air temperature in response to building loads, or to outdoor air temperature.
2. Controls shall reset the supply air temperature at least 25% of the difference between the design supply air temperature and the design room air temperature.

**Exception:**

*Climate zone - Warm-humid*

03 Feb 2016 - Bengaluru

ECBC Update 2016

197

## Chilled Water Temperature Reset (EE & SEE)

1. Chilled water system with a design capacity exceeding 87.5 kW (25 TR) supplying chilled water to comfort conditioning systems
  - a. Shall include controls that automatically reset supply water temperatures by representative building loads (including return water temperature) or by outdoor air temperature.

**Exception:**

- *Where the supply temperature reset controls causes improper operation of equipment.*
- *Hydronic systems that uses variable flow to reduce pumping energy*

03 Feb 2016 - Bengaluru

ECBC Update 2016

198

## VAV fan control (SEE building)

- a. The fan shall have controls or devices that will result in fan motor demand of no more than 30 % of their design wattage at 50 % of design airflow when static pressure set point equals one-third of the total design static pressure, based on manufacturer's certified fan data.

## Air side economizer control (SEE building)

- ✓ Economizer dampers shall be sequenced with the mechanical cooling equipment and shall not be controlled by only mixed air temperature.
- ✓ Air economizers shall be capable of automatically reducing outdoor air intake to the design minimum outdoor air quantity when outdoor air intake will no longer reduce cooling energy usage.
  - ✓ Specify High-limit shutoff

## Pipe insulation (Mandatory for all hotels, all hospitals, and buildings with BUA >10,000 m<sup>2</sup>)

**Pipe Insulation with Minimum R-value (m<sup>2</sup>-K/W)** Steam, steam condensate, hot water, domestic water, and cooling system like chilled water, brine, and refrigerant)

<b>Heating System</b>	ECBC 2007	ECBC 2016		EE Building		SEE building	
Operating Temp/ pipe size (mm)	All size	< 40	>= 40	< 40	>=40	< 40	>=40
94°C to 121°C	0.74	0.9	1.2	1.1	1.3	1.5	1.5
60°C to 94°C	0.74	0.7	0.7	0.8	0.8	1.0	1.3
40°C to 60°C	0.35	0.4	0.7	0.5	0.9	0.7	1.1
<b>Cooling System</b>	ECBC						
Operating Temp/ pipe size (mm)	All size	< 25	40-100	< 25	40-100	< 25	40-100
4.5°C to 15°C	0.35	0.4	0.7	0.5	0.9	0.7	1.2
< 4.5°C	0.35	0.9	1.2	1.1	1.3	1.5	1.5
<b>Refrigerant Piping</b>	ECBC						
Split System		< 25	40-100	< 25	40-100	< 25	40-100
4.5°C to 15°C	0.35	0.4	0.7	0.5	0.9	0.4	0.7
< 4.5°C	0.35	0.9	1.2	1.1	1.3	1.5	1.5

27 May 2016 - Delhi

ECBC Update 2016

201

## Pipe insulation (Conti..)

- a. For any pipe located in partition within a conditioned space or buried,
  - a. a reduction in R value by 0.2 shall be permitted but not less than R - 0.4
- b. For any pipe located in partition outside a building with a direct exposure to external atmosphere, direct sun, shall require
  - a. an additional R value of 0.2 over and above the requirement stated in the table in previous slide
- c. For building in temperate climate zone,
  - a. a reduction in R value by 0.2 shall be permitted compared to values in table in previous slide but not less than R - 0.4

27 May 2016 - Delhi

ECBC Update 2016

202

## Duct insulation (Mandatory for all hotels, all hospitals, and buildings with BUA>10,000 m<sup>2</sup>)

Duct Location	ECBC 2007		ECBC 2016 (Min performance)		EE building		SEE building	
	Supply Ducts	Return Ducts	Supply ducts	Return ducts	Supply ducts	Return ducts	Supply ducts	Return ducts
Exterior	R-1.4	R-0.6	R-1.4	R-0.6	R-1.4	R-0.6	R-1.4	R-0.6
Unconditioned Space	R-0.6	None	R-0.6	None	R-0.6	None	R-0.6	None
Buried	R-0.6	None	R-0.6	None	R-0.6	None	R-0.6	None

Required Insulation (R-values in m<sup>2</sup>-K/W)

## Design

1. Ventilation/ Fresh air
2. Exhaust
3. Natural ventilation

# Ventilation

27 May 2016 - Delhi

ECBC Update 2016

205

## Ventilation (Mandatory)

1. Natural ventilation
2. Mechanical Ventilation
3. Exhaust

No requirement of ventilation in ECBC 2007

27 May 2016 - Delhi

ECBC Update 2016

206

## Ventilation

### 1. General Requirements.

All habitable spaces shall be ventilated in accordance with the requirements of this section and the outdoor air-ventilation rate of NBC.

### 2. Design Requirements.

Every space shall be designed to have outdoor air ventilation according to natural ventilation or mechanical ventilation:

27 May 2016 - Delhi

ECBC Update 2016

207

## Natural Ventilation

1. permanent openings, windows, doors, louvers, etc
2. Targeted area should be no more than 14 m from the operable wall or roof openings
3. Unobstructed openable area of which is not less than 5% of the conditioned floor area of the naturally ventilated space.
4. All installed ceiling fans should be of minimum 3 star rated
5. Openable area shall be based on the free unobstructed area.

**EXCEPTIONS:** Naturally ventilated spaces in hotel/motel guest rooms shall be open to and within 8 m of operable wall or roof openings to the outdoors.

27 May 2016 - Delhi

ECBC Update 2016

208



## Mechanical Ventilation

### 1. Mechanical ventilation – system capable of providing an outdoor air rate no less than:

- a. The conditioned floor area of the space times the applicable ventilation rate from NBC

*Exception: Transfer air – air could be transferred from other ventilated spaces if:*

- Space having no sources of indoor air contaminants; and
- The outdoor air that is supplied to all spaces combined, is sufficient to meet the requirements of NBC for each space individually.

## Ventilation

### Operation and Control Requirements for Minimum Quantities of Outdoor Air.

- a. **Times of occupancy.** all times when the space is occupied.

*Exception 1: Demand control ventilation.*

*Exception 2: Temporary reduction. The average rate for each hour should be  $\geq$  than the required ventilation rate.*

## Ventilation

### Demand Control Ventilation. Applicable if:

- a. Occupant density  $\geq 40$  people per 100 m<sup>2</sup>;

**Exception 1:** Classrooms, call centers, continuously occupied office spaces, healthcare facilities and medical buildings, and public areas of social services buildings

**Exception 2:** Spaces that have processes or operations that generate dusts, fumes, mists, vapors, or gases and are not provided with local exhaust ventilation, such as indoor operation of internal combustion engines or areas designated for unvented food service preparation, or beauty salons shall not install demand control ventilation.

**Exception 3:** Spaces with an area of less than 15 m<sup>2</sup>, or a design occupancy of less than 10 people per NBC standard recommendations.

## Low energy comfort system and other supporting EE equipment

1. Evaporative cooling
2. Economizer
3. Heat recovery

## Other low energy comfort systems

1. Evaporative Cooling
2. Desiccant cooling system
3. Solar air conditioning
4. Tri- generation (Waste to heat)
5. Radiant cooling system
6. Ground source heat pump
7. Adiabatic cooling system

### Discussion point -

Incentive - Building installing any of the above low energy comfort system would be exempted from the mandatory requirements of comfort systems and control section

27 May 2016 - Delhi

ECBC Update 2016

213

Session 6

# Electrical and Renewable

## Key Highlights

1. Integration of renewable energy requirement
2. Integration of other Indian standards (IS standards) and BEE studies with ECBC to have similar requirements
3. Advance metering and sub metering requirements

27 May 2016 - Delhi

ECBC Update 2016

215

## Electrical and Renewable – revised scope (All mandatory – discussion points)

- Equipment efficiency and design
  - a. Transformers
  - b. Motors
  - c. Power Factor
  - d. Electrical Metering and Monitoring
  - e. Electrical Distribution Systems
  - f. DG sets
  - g. Voltage Unbalancing
  - h. Harmonic Distortion
  - i. Size of Neutral Conductors
  - j. Uninterruptible Power Supply
- Renewable Energy
- Hot water
  - a. Solar
  - b. Other hot water equipment

27 May 2016 - Delhi

ECBC Update 2016

216

## Transformers

- a. Minimum acceptable efficiency at 50% and full load rating.
- b. Oil type transformer – as per IS 1180 (up to and including 33kV)
  - a. Voltage class 11 kV to 22 kV, the permissible total loss values < 5%
  - b. Voltage class 22 kV to 33 kV, the permissible total loss values < 7.5%
- c. Dry type transformer – as per IS 11171

### Voltage Drop

- a. **Feeders.** maximum *voltage drop* of 2% at design load.
- b. **Branch circuit:** maximum *voltage drop* of 3% at design load.

27 May 2016 - Delhi

ECBC Update 2016

217

## Transformers

### Measurement and Reporting of Transformer Losses

- Use calibrated digital meters of class 0.2 or better and certified by the manufacturer for all measurement of losses
- All transformers of capacity of 500 kVA and above would be equipped with additional metering class current transformers (CTs) and potential transformers (PTs) additional to need of Utilities so that periodic loss monitoring study may be carried out.

27 May 2016 - Delhi

ECBC Update 2016

218

## Motors

ECBC 2016 requirement is fulfilled by the minimum requirement stated in the IS 12615. For all building type, size, and climate zone

- ECBC 2016 – IE 2
  - Energy efficient (EE) building – IE 3
  - Super EE building – IE 4
- Motor horsepower ratings shall not exceed 20% of the calculated maximum load being served
  - Motor nameplates shall list the nominal full-load motor efficiencies and the full-load power factor

## DG Sets

1. BEE star rated product is mandatory for the ECBC compliance
2. For all building greater than 20,000 m<sup>2</sup>
  - a. ECBC 2016 requirement – minimum 3 star rated product
  - b. EE requirement – minimum 4 star rated product
  - c. SEE requirement – minimum 5 star rated product

# Power Factor Correction

27 May 2016 - Delhi

ECBC Update 2016

221

## Power Factor Correction

All electricity supplies exceeding 100 A, 3 phases shall maintain their power factor range at the point of connection as below:

ECBC 2016 recommendation level

- ECBC 2016 (MEPs) – 0.97
- Energy efficient (EE) building – 0.98
- Super EE building – 0.99

What should be recommended value for True RMS power factor? – Discussion point (0.97/ 0.95)

27 May 2016 - Delhi

ECBC Update 2016

222

# Metering and Monitoring

27 May 2016 - Delhi

ECBC Update 2016

223

## Sub metering

	120 kVA to 250 kVA	250 kVA to 600 kVA	more than 600 kVA
Minimum requirement for metering of electrical load			
Energy kWh	Required	Required	Required
Demand kVA	Required	Required	Required
Total power factor	Required	Required	Required
Minimum requirement for separation of Electrical Load			
HVAC system and components	Required	Required	Required
Lighting (interior and exterior)	Required	Required	Required
Domestic hot water	Not required	Required	Required
Plug loads	Not required	Required	Required
Renewable power source	Required	Required	Required
Mandatory requirement for building type over the requirement stated above			
Commercial mall/ retail	Façade lighting	Elevator, escalators, moving walks	
Offices	Data centers		
Hotels	Commercial kitchens		
In case of tenant based building, metering should be provided as per the above requirement at a location from where each tenant could attach the services.			

27 May 2016 - Delhi

ECBC Update 2016

224



# Power Distribution System

27 May 2016 - Delhi

ECBC Update 2016

225

## Power distribution system

The power cabling shall be adequately sized as to maintain the distribution losses not to exceed 3% of the total Power usage. Record of design calculation for the losses shall be maintained.

### ECBC 2016 recommendation level

- |                                  |        |
|----------------------------------|--------|
| – Minimum performance building   | – 3.0% |
| – Energy efficient (EE) building | – 2.0% |
| – Super EE building              | – 1.5% |

Load calculation to be calculated up to the panel level

27 May 2016 - Delhi

ECBC Update 2016

226

# Voltage Unbalancing

27 May 2016 - Delhi

ECBC Update 2016

227

## Voltage Unbalancing – Definition

In a three-phase system, the degree of voltage unbalance is expressed by the ratio (in per cent) between the RMS values of the negative sequence component and the positive sequence component of the voltage. This ratio may be approximated as:

Voltage unbalance (%) =

$$\frac{\text{Maximum deviation from the average of the three-phase voltages} \times 100\%}{\text{average of the three-phase voltages}}$$

27 May 2016 - Delhi

ECBC Update 2016

228

## Voltage Unbalancing – ECBC 2016 recommendation

- ECBC 2016 will limit the voltage unbalance in distribution networks operating at 33kV and below.
- voltage unbalance to be measured in relation to the negative phase sequence component of the supply voltage.
- The magnitude of the negative phase sequence component is **within 2% of the positive phase sequence** component then the unbalance is acceptable.
- This limit is to be taken for the combined affect of all new and existing loads at the point of common coupling

27 May 2016 - Delhi

ECBC Update 2016

229

## Compliance requirement – (Discussion point)

unbalanced three-phase loads or phase to phase loads may be evaluated by the following expression

$$VU (\%) = \frac{\sqrt{3} \times \text{negative phase sequence Component of the loads (A)} \times \text{line voltage} \times 100\%}{\text{Three-phase short circuit level at exit point (MVA)}}$$

load connected only between two phases may be calculated as

$$VU (\%) = \frac{\text{single phase load (MVA)} \times 100\%}{\text{three phase short circuit level (MVA) at that point}}$$

- Measurement Interval = 10 mins
- Monitoring Period = 1 week
- Acceptance Percentage = 95%

27 May 2016 - Delhi

ECBC Update 2016

230

# Total Harmonic Distortion

27 May 2016 - Delhi

ECBC Update 2016

231

## Total Harmonic Distortion

1. Total Harmonic Distortion (THD)
2. Total Demand Distortion (TDD)

The ratio  $I_{sc}/I_L$  is the ratio of the short-circuit available at the point of common coupling (PCC), to the maximum fundamental load current.

27 May 2016 - Delhi

ECBC Update 2016

232

## Total Harmonic Distortion (THD)

System Voltage at the PCC	THD Limit
1. 400V	5%
2. 6.6, 11 and 20kV	4%
3. 22kV to 400kV	3%

27 May 2016 - Delhi

ECBC Update 2016

233

## Total Demand Distortion

### Individual harmonic order (odd harmonics)

1.	$I_{sc}/I_L$	TDD
2.	<20*	5.0
3.	20<50	8.0
4.	50<100	12.0
5.	100<1000	15.0
6.	>1000	20.0

Even harmonic are limited to 25% of the odd harmonic limits above.

1. Current distortions that result in a dc offset, e.g. half-wave converters are not allowed.
2. \*All power generation equipment is limited to these values of distortion, regardless of act
3. Where
  - $I_{sc}$  = maximum short-circuit current at PCC.
  - $I_L$  = maximum demand load current (fundamental frequency component) at PCC

27 May 2016 - Delhi

ECBC Update 2016

234

# Neutral conductors

27 May 2016 - Delhi

ECBC Update 2016

235

## Neutral Conductors

Comply with the prescribed requirement of National Electrical Code (latest version)

For a polyphase circuit in which imbalance may occur in normal service, through significant inequality of loading or of power factor in the various phases, or through the presence of significant harmonic currents in the various phases, the neutral conductor shall have a cross-sectional area adequate to afford compliance with permissible conductor operating temperature for the maximum current likely to flow in it.

27 May 2016 - Delhi

ECBC Update 2016

236

# Uninterruptible Power Supply (UPS)

27 May 2016 - Delhi

ECBC Update 2016

237

## UPS energy efficiency requirement

1. ECBC to introduce the EE requirements for any UPS used in the buildings greater than 10,000 m<sup>2</sup>
2. Future S&L requirement to take precedence
3. UPS Size                      EE requirement on 100% Load
 

a. kVA < 20	90.2%
b. 20 ≤ kVA ≤ 100	91.9%
c. kVA > 100	93.8%
4. Discussion point – Compliance?

27 May 2016 - Delhi

ECBC Update 2016

238

# Renewable Energy

27 May 2016 - Delhi

ECBC Update 2016

239

## Renewable Energy Integration

1. RE systems include technologies designed to capture solar, wind, geo-thermal, water, or bio based energy to satisfy onsite electric power demand.
2. ECBC to limit itself to the onsite RE generation only.  
Purchase of RE certificate to be considered only after the concerned legislation is notified by the Center or the State Government

27 May 2016 - Delhi

ECBC Update 2016

240



## RE provisions for future installation (Mandatory)

All buildings applicable to ECBC 2016 will have mandatory provisions of future installation of renewable energy. Compliance requirement-

1. **Minimum area** - Dedicate a minimum area as RE zone
  - For non-residential: Least of, area > 10 % of roof area or area required for the generation of energy equivalent to 1% of total peak demand or connected load
  - Exceptions: If have solar hot water/ solar electric systems
2. **Shading** –
  - No obstructions shall be located in the RE zone.
3. **Main Electrical Service Panel**
  - shall have a minimum rating for amps
  - shall have a reserved space to allow for the installation of a double pole circuit breaker for a future solar electric installation

27 May 2016 - Delhi

ECBC Update 2016

241

## RE provisions for future installation (Mandatory)

4. **Provision of highlighted on construction documents:**
  - location for inverters and metering equipment
  - pathway for routing of conduit from the RE zone to the point of interconnection with the electrical service.
  - routing of plumbing from the RE zone to the water-heating system.
  - structural design loads for roof dead load and roof live load

27 May 2016 - Delhi

ECBC Update 2016

242

## EE requirement

- a. EE building scope for RE will be divided into 2 parts:
- PART 1 - Fulfil all requirements of MEPs
    - Mandatory 2% of total electricity demand to be generated on site through renewable energy
  - PART 2 - Mandatory 3% of total electricity demand to be generated on site through renewable energy for following:
    - Hotels/ Motels over 25,000 m<sup>2</sup>
    - Resorts over 12,500 m<sup>2</sup>
    - University over 30,000 m<sup>2</sup>
    - IT parks and offices over 30,000 m<sup>2</sup>

27 May 2016 - Delhi

ECBC Update 2016

243

## SEE Requirement

- a. SEE building scope for RE will be divided into 2 parts:
- PART 3 - Fulfil all requirements of MEPs
    - Mandatory 4% of total electricity demand to be generated on site through renewable energy
  - PART 4 - Mandatory 6% of total electricity demand to be generated on site through renewable energy for following:
    - Hotels/ Motels over 25,000 m<sup>2</sup>
    - Resorts over 12,500 m<sup>2</sup>
    - University over 30,000 m<sup>2</sup>
    - IT parks and offices over 30,000 m<sup>2</sup>

27 May 2016 - Delhi

ECBC Update 2016

244

# Service Hot Water

Solar  
Other hot water equipment

27 May 2016 - Delhi

ECBC Update 2016

245

## Solar hot water

### ➤ Solar water heating

- For facilities like hotels and hospitals with a centralized system
- If building area < 20,000 m<sup>2</sup>, at least 20% of the design capacity
- If building area > 20,000 m<sup>2</sup>, at least 40% of the design capacity

*Exception to above:*

- *Systems that use heat recovery for at least 40% of the design hot water capacity.*

### ➤ Equipment efficiency

- Solar water heater - IS 13129 Part
- Gas Instantaneous Water heaters - IS 15558
- Electric water heater - IS 2082

27 May 2016 - Delhi

ECBC Update 2016

246

## ECBC 2016

- Supplementary heating system
  - Maximum heat recovery from hot discharge system like condensers of air conditioning units
  - Use of gas-fired heaters wherever gas is available
  - Electric heater as last resort
- Heat Traps
- Swimming pools
  - If heated to  $> 32^{\circ}\text{C}$  ( $90^{\circ}\text{F}$ ), then minimum insulation value of **R-4.1**
    - Exception to above: Pools deriving over 60% of their energy from site-recovered energy or solar energy source.

27 May 2016 - Delhi

ECBC Update 2016

247

## Feedback

1. Technical committee is required to provide feedback on
  - a. Approach
  - b. Scope
  - c. Draft recommendations
  - d. Compliance

27 May 2016 - Delhi

ECBC Update 2016

248

## Key highlights of ECBC 2016 – Summary of key changes in ECBC 2007

Integration of all other current and future Government Policies, relevant standards

### New sections in ECBC 2016-

ECBC 2016 to have an International benchmark  
Code specific to Indian conditions – Climatic and Construction  
Pave the way for future nZEB

3 different sets of requirement – ECBC 2016 MEPs, EE buildings, SEE buildings

Wider scope in Comfort systems and controls, Integration of low energy comfort systems, natural ventilation, set points, Controls  
Wider scope for Electrical & Renewable

Daylighting, Shading requirement with relaxed U value

Focus on compliance and enforcement

Integration of Renewable Energy and integration of IS standards

More relevant spaces included in the LPD requirement. Focus on controls

Comprehensive list of definitions to avoid manipulation and Focused compliance forms

Compliance for New Construction, Core & Shell, Tenant lease type etc

27 May 2016 - Delhi

ECBC Update 2016

249

**For any comments, concerns, and feedback,  
please contact  
Girija Shankar, BEE, at [gshankar@beenet.in](mailto:gshankar@beenet.in) or  
Govinda Somani, EDS, at [govinda@edsglobal.com](mailto:govinda@edsglobal.com)**

**The presentation and template to provide  
comments is uploaded on BEE's website  
<https://beeindia.gov.in/content/new-construction>**

27 May 2016 - Delhi

ECBC Update 2016

250

# Discussion and way forward

27 May 2016 - Delhi

ECBC Update 2016

251

# Thank you

PACE-D TA TEAM

27 May 2016 - Delhi

ECBC Update 2016

252